

Generator Set Data Sheet

Model: 2000GQNC

Frequency: 50 Hz

Fuel Type: Natural Gas MI 75 +

Emissions Performance NOx: 250 mg/Nm³ (0.6 g/hp-h)

LT Water Inlet Temperature: 50°C (122°F)

HT Water Outlet Temp: 92°C (198°F)

Measured Sound Performance Data Sheet:	MSP-1039
Prototype Test Summary Data:	PTS-269
Remote Radiator Cooling Outline:	0500-4327

Fuel Consumption (ISO3046/1)	See Note	100% of Rated Load	90% of Rated Load	75% of Rated Load	50% of Rated Load
Fuel Consumption (LHV) ISO3046/1, kW (MMBTU/hr)	2,4,6,7	5019 (17.14)	4576 (15.63)	3899 (13.32)	2819 (9.63)
Mechanical Efficiency ISO3046/1, percent	2,4,7	41.2%	40.6%	39.8%	36.9%
Electrical Efficiency ISO3046/1, percent	2,4,6,7	39.8%	39.3%	38.5%	35.5%

Engine	
Engine Manufacturer	Cummins
Engine Model	QSV91G
Configuration	V18
Displacement, L (cu.in)	91.6 (5591)
Aspiration	Turbocharged (1)
Gross Engine Power Output, kWm (hp)	2066 (2769)
BMEP, bar (psi)	18.3 (265)
Bore, mm (in)	180 (7.09)
Stroke, mm (in)	200 (7.87)
Rated Speed, rpm	1500
Piston Speed, m/s (ft/min)	10 (1968)
Compression Ratio	12.5
Lube Oil Capacity, L (qt)	550 (581)
Overspeed Limit, rpm	1800
Regenerative Power, kW	N/A
Full Load Lubricating oil consumption, g/kWe-hr (g/hp-hr)	0.4 (03)
Fuel	
Gas supply pressure to engine inlet, bar (psi)	.15-20 (2.2 - 2.9)
Minimum Methane Index	75
Starting System(s)	
Electric starter voltage, volts	24
Minimum battery capacity @ 40 deg.C (104 deg.F), AH	780
Air Starter Pressure, barg (psig)	10.3 (150)
Air Starter Flow Nm ³ /s (scfm)	0.37 (780)
Genset Dimensions (see note 1)	
Genset Length, m (ft)	6.07 (19.9)
Genset Width, m (ft)	2.16 (7.1)
Genset Height, m (ft)	2.78 (9.1)
Genset Weight (wet), kg (lbs)	20457 (45,100)

	See Notes	100% of Rated Load	90% of Rated Load	75% of Rated Load	50% of Rated Load
Energy Data					
Continuous Shaft Power, kWm (bhp)	2,10	2066 (2770)	1860 (2493)	1551 (2079)	1040 (1393)
Continuous Generator Electrical Output kWe @ 1.0 pf	6,10	2000	1800	1500	1000
Heat Dissipated in Lube Oil Cooler, kW (MMBTU/h)	5	279 (0.95)	252 (0.86)	228 (0.78)	188 (0.64)
Heat Dissipated in Block, kW (MMBTU/h)	5	530 (1.81)	495 (1.69)	470 (1.60)	391 (1.33)
Total Heat Rejected in LT Circuit, kW (MMBTU/h)	5	142 (0.48)	125 (0.43)	114 (0.39)	87 (0.30)
Total Heat Rejected in HT Circuit, kW (MMBTU/h)	5	1183 (4.04)	1042 (3.56)	889 (3.03)	630 (2.15)
Unburnt, kW (MMBTU/h)	13	137 (0.47)	125 (0.43)	107 (0.36)	75 (0.26)
Heat Radiated to Ambient, kW (MMBTU/h)	13	327 (1.11)	297 (1.01)	254 (0.87)	186 (0.63)
Available Exhaust heat to 105C, kW (MMBTU/h)	5	1264 (4.31)	1162 (3.97)	1025 (3.50)	802 (2.74)
Intake Air Flow					
Intake Air Flow Mass, kg/s (lb/hr)	4	3.28 (25959)	2.94 (23313)	2.46 (19474)	1.67 (13215)
Intake Air Flow Volume, m3/s @ 0°C (scfm)	4	2.53 (5660)	2.28 (5083)	1.90 (4246)	1.29 (2882)
Maximum Air Cleaner Restriction, mmHG (in H ₂ O)		22 (11.8)	22 (11.8)	22 (11.8)	22 (11.8)
Exhaust Air Flow					
Exhaust Gas Flow Mass, kg/s (lb/hr)	4	3.39 (26859)	3.05 (24137)	2.55 (20175)	1.73 (13716)
Exhaust Gas Flow Volume, m3/s (cfm)	4	6.96 (14727)	6.34 (13424)	5.43 (11496)	3.91 (8284)
Exhaust Temperature After Turbine, °C (°F)	2,6	451 (844)	462 (863)	480 (895)	525 (976)
Max Exhaust System Back Pressure, mmHG (in H ₂ O)	6,14	37.3 (20.0)	37.3 (20.0)	37.3 (20.0)	37.3 (20.0)
Min Exhaust System Back Pressure, mmHG (in H ₂ O)	6,14	18.7 (10.0)	18.7 (10.0)	18.7 (10.0)	18.7 (10.0)
HT Cooling Circuit					
HT Circuit Engine Coolant Volume, l (gal)		424 (112)	424 (112)	424 (112)	424 (112)
HT Coolant Flow @ Max Ext Restriction, m ³ /h (gal/min)		70 (308)	70 (308)	70 (308)	70 (308)
Max HT Engine Coolant Inlet Temp, °C (°F) Reference	8	75 (167)	75 (167)	75 (167)	75 (167)
HT Coolant Outlet Temp, °C (°F)	8	92 (198)	92 (198)	92 (198)	92 (198)
Max Pressure Drop in External HT Circuit, bar (psig)		1.5 (22)	1.5 (22)	1.5 (22)	1.5 (22)
HT Circuit Maximum Pressure, bar (psig)		6.0 (87)	6.0 (87)	6.0 (87)	6.0 (87)
Minimum Static Head, bar (psig)		0.5 (7)	0.5 (7)	0.5 (7)	0.5 (7)
LT Cooling Circuit					
LT Circuit Engine Coolant Volume, l (gal)		295 (78)	295 (78)	295 (78)	295 (78)
LT Coolant Flow @ Max Ext Restriction, m ³ /h (gal/min)		50.00 (220)	50.00 (220)	50.00 (220)	50.00 (220)
Maximum LT Engine Coolant Inlet Temp, °C (°F)	9	50 (122)	50 (122)	50 (122)	50 (122)
LT Coolant Outlet Temp, °C (°F) Reference Only	9	52.2 (126)	52.0 (126)	51.7 (125)	51.4 (125)
Max Pressure Drop in External LT Circuit, bar (psig)		1.5 (22)	1.5 (22)	1.5 (22)	1.5 (22)
LT Circuit Maximum Pressure, bar (psig)		6.0 (87)	6.0 (87)	6.0 (87)	6.0 (87)
Minimum Static Head, bar (psig)		0.5 (7)	0.5 (7)	0.5 (7)	0.5 (7)
Emissions					
NO _x Emissions wet, ppm	5	82	81	79	83
NO _x Emissions at Exhaust Condition, mg/Nm ³ (g/hp-h)	5	260 (0.57)	257 (0.56)	251 (0.55)	256 (0.60)
THC Emissions wet, ppm	13	1640	1665	1702	1765
THC Exhaust Emissions, mg/Nm ³ (g/hp-h)	13	1792 (3.91)	1811 (3.95)	1836 (4.05)	1841 (4.31)
CH ₄ Emissions wet, ppm	13	1241	1257	1277	1312
CH ₄ Emission, mg/Nm ³ (g/hp-h)	13	1378 3.01	1388 3.03	1399 3.09	1389 3.25
NMHC Emissions wet, ppm	13	399	409	425	454
NMHC Exhaust Emissions, mg/Nm ³ (g/hp-h)	13	436 0.95	445 0.97	459 1.01	473 1.11
CO Emissions (dry), ppm	13	582	570	561	526
CO Emissions Rate at Exhaust Condition, mg/Nm ³	13	1003 (2.19)	977 (2.13)	953 (2.10)	859 (2.01)
O ₂ Emissions (dry), percent	13	9.4	9.3	9.2	8.7
Particulates PM10, g/hp-h	13	Not recorded	Not recorded	Not recorded	Not recorded

Genset De-rating

Altitude and Temperature Derate Multiplication Factor

Barometer		Altitude		Table A *											
In Hg	mbar	Feet	Meters	Derate Multiplier with Grid Parallel Operation											
20.7	701	9843	3000												
21.4	723	9022	2750												
22.1	747	8202	2500	0.75	0.75										
22.8	771	7382	2250	0.80	0.80										
23.5	795	6562	2000	0.85	0.85	0.75									
24.3	820	5741	1750	0.90	0.90	0.80									
25.0	846	4921	1500	0.95	0.95	0.85	0.75								
25.8	872	4101	1250	1.00	1.00	0.90	0.80								
26.6	899	3281	1000	1.00	1.00	0.95	0.85	0.75							
27.4	926	2461	750	1.00	1.00	1.00	0.90	0.80							
28.3	954	1640	500	1.00	1.00	1.00	0.95	0.85							
29.1	983	820	250	1.00	1.00	1.00	1.00	0.90							
29.5	995	492	150	1.00	1.00	1.00	1.00	0.95	0.75						
30.0	1012	0	0	1.00	1.00	1.00	1.00	1.00	0.80						
				°C	20	25	30	35	40	45	50	55	60		
				°F	68	77	86	95	104	113	122	131	140		
Air Filter Inlet Temperature															

Temperature & Altitude Derate

- Determine derate multiplier vs. temperature and altitude in Table A or B depending upon your operating condition.
- Assumes the LT return temperature is 10 deg C above the air filter inlet with a maximum LT temperature of 50 deg C.
- If the LT temperature exceeds 50 deg C, consult factory for recommendations.
- Altitude is based upon SAE standard ambient pressure vs. altitude. For low barometric conditions add 150m (500 ft) to site altitude.

* Based on SAE standard ambient pressure vs. altitude. Assumes LT return temperature is 10C above air filter inlet.

Barometer		Altitude		Table B *											
In Hg	mbar	Feet	Meters	Derate Multiplier Off Grid (Island or Load Share)											
20.7	701	9843	3000												
21.4	723	9022	2750												
22.1	747	8202	2500	0.75	0.75										
22.8	771	7382	2250	0.80	0.80										
23.5	795	6562	2000	0.85	0.85	0.75									
24.3	820	5741	1750	0.90	0.90	0.80									
25.0	846	4921	1500	0.95	0.95	0.85	0.75								
25.8	872	4101	1250	1.00	1.00	0.90	0.80								
26.6	899	3281	1000	1.00	1.00	0.95	0.85	0.75							
27.4	926	2461	750	1.00	1.00	1.00	0.90	0.80							
28.3	954	1640	500	1.00	1.00	1.00	0.95	0.85							
29.1	983	820	250	1.00	1.00	1.00	1.00	0.90							
29.5	995	492	150	1.00	1.00	1.00	1.00	0.95	0.75						
30.0	1012	0	0	1.00	1.00	1.00	1.00	1.00	0.80						
				°C	20	25	30	35	40	45	50	55	60		
				°F	68	77	86	95	104	113	122	131	140		
Air Filter Inlet Temperature															

Methane Number Capability			
Load (Percent of Rated)			
100%	90%	75%	50%
75	69	n/a	n/a

* Based on SAE standard ambient pressure vs. altitude. Assumes LT return temperature is 10C above air filter inlet.

Heat Rejection Factor (altitude and ambient) for HT and LT Circuits

Barometer		Altitude		Table C											
In Hg	mbar	Feet	Meters	Multiplier for HT & LT Heat Rejection vs Alt & Temp.											
20.7	701	9843	3000	1.11	1.13	1.14	1.15	1.17	1.18	1.19	1.20	1.22			
21.4	723	9022	2750	1.10	1.12	1.13	1.14	1.15	1.17	1.18	1.19	1.21			
22.1	747	8202	2500	1.09	1.10	1.12	1.13	1.14	1.16	1.17	1.18	1.20			
22.8	771	7382	2250	1.08	1.09	1.11	1.12	1.13	1.14	1.16	1.17	1.18			
23.5	795	6562	2000	1.07	1.08	1.09	1.11	1.12	1.13	1.15	1.16	1.17			
24.3	820	5741	1750	1.06	1.07	1.08	1.10	1.11	1.12	1.14	1.15	1.16			
25.0	846	4921	1500	1.05	1.06	1.07	1.09	1.10	1.11	1.12	1.14	1.15			
25.8	872	4101	1250	1.04	1.05	1.06	1.07	1.09	1.10	1.11	1.13	1.14			
26.6	899	3281	1000	1.02	1.04	1.05	1.06	1.08	1.09	1.10	1.12	1.13			
27.4	926	2461	750	1.01	1.03	1.04	1.05	1.07	1.08	1.09	1.10	1.12			
28.3	954	1640	500	1.00	1.02	1.03	1.04	1.05	1.07	1.08	1.09	1.11			
29.1	983	820	250	0.99	1.00	1.02	1.03	1.04	1.06	1.07	1.08	1.10			
29.5	995	492	150	0.99	1.00	1.01	1.03	1.04	1.05	1.06	1.08	1.09			
30.0	1012	0	0	0.98	0.99	1.01	1.02	1.03	1.05	1.06	1.07	1.08			
				°C	20	25	30	35	40	45	50	55	60		
				°F	68	77	86	95	104	113	122	131	140		
Air Filter Inlet Temperature															

LT & HT Circuit Heat Rejection Calculation

- Determine derate multiplier vs. temperature derate per above.
- Using the multiplier from #1 above as the percent load factor determine the Heat rejection from the previous page.
- From Table C find the HT and LT circuit multiplier.
- Multiply the result of step 2 by the result of step 3 to obtain the heat rejection at your altitude and temperature.

Alternator Data							
Voltage Range	Connection Configuration	Temp Rise Degrees C	Duty ¹¹ Cycle	Single Phase Factor	Maximum Surge kVA ¹²	Alternator Data Sheet	Feature Code
380-440	Wye, 3 Phase	105	C	N/A	9720	517	B551-2
400-415	Wye, 3 Phase	105	C	N/A	6758	516	B792-2
380-440	Wye, 3 Phase	125	C	N/A	6758	516	B584-2
3300	Wye, 3 Phase	80	C	N/A	7040	520	B592-2
3300	Wye, 3 Phase	105	C	N/A	6316	519	B471-2
6600	Wye, 3 Phase	80C	C	N/A	7040	520	B828-2
6600	Wye, 3 Phase	105	C	N/A	6076	522	B793-2
6300-6600	Wye, 3 Phase	105	C	N/A	6932	523	B576-2
10000	Wye, 3 Phase	80	C	N/A	6627	523	B794-2
10000	Wye, 3 Phase	105	C	N/A	5812	522	B474-2
10.5-11.0 kV	Wye, 3 Phase	105	C	N/A	6784	523	B495-2
11000	Wye, 3 Phase	80	C	N/A	6784	523	B594-2
11000	Wye, 3 Phase	105	C	N/A	5896	522	B478-2

Continuous Rating Definition

Applicable for supplying power continuously to a constant load up to the full output rating for unlimited hours. No sustained overload capability is available for this rating. Consult authorized distributor for rating. (Equivalent to Continuous Power in accordance with ISO8528, ISO3046, AS2789, DIN6271, and BS5514). This rating is not applicable to all generator set models.

Notes

- 1) Weights and set dimensions represent a generator set with its standard features only. See outline drawing for other configurations.
- 2) At ISO3046 reference conditions, altitude 1013 mbar (30in Hg), air inlet temperature 25 °C (77°F)
- 3) Nominal performance $\pm 2 \frac{1}{2}\%$.
- 4) According to ISO 3046/I with fuel consumption tolerance of +5% -0% or efficiency tolerance of +0% -5%.
- 5) Production variation/tolerance $\pm 5\%$.
- 6) At electrical output of 1.0 Power Factor.
- 7) Tested using pipeline natural gas with LHV of 33.44mJ/Nm³ (905BTU/ft³)
- 8) Outlet temperature controlled by thermostat. Inlet temperature for reference only.
- 9) Inlet temperature controlled by thermostat, outlet temperature for reference only.
- 10) With engine driven coolant pump.
- 11) Standby (S), Prime (P), Continuous (C)
- 12) Maximum rated starting kVA that results in minimum of 90% of rated sustained voltage during starting.
- 13) Tolerance +/- 15%
- 14) Exhaust system back pressure is a rated load and will decrease at lower loads.



See your distributor for more information.

Cummins Power Generation
 1400 73rd Avenue N.E.
 Minneapolis, MN 55432 USA
 Telephone: +1 (763) 574-5000
 Fax: +1 (763) 574-5298
 Email: pgamail@cummins.com
 Web: www.cumminspowergeneration.com

Cummins Power Generation
 Manston Park, Columbus Avenue
 Manston, Ramsgate
 Kent CT12 5BF, UK
 Telephone: +44 (0) 1843 255000
 Fax: +44 (0) 1843 255902
 E-Mail: cpg.uk@cummins.com
 Web: www.cumminspower.com

Cummins Power Generation
 8 Tanjong Penjuru
 Singapore 609019
 Telephone: +65 265-0155
 Fax: +65 264-0664 or 265-6909
 Email: mktg@sing.cummins.com

Cummins and PowerCommand are registered trademarks of Cummins Inc. AmpSentry is a trademark of Cummins Inc.

Important: Back feed to a utility system can cause electrocution and/or property damage. Do not connect to any building's electrical system except through an approved device or after building main switch is open.